

## 903000017 CONVERSION KIT INSTRUCTIONS


### **SE+ Series (Model RSEP1S35N) NG TO LP**

TOOLS REQUIRED: 11/16" or 19mm Box Wrench  
Slot or Flat Screwdriver  
¼" Nut Driver



**WARNING: This Kit to be installed only by a qualified service agency.**

#### **IMPORTANT:**

- **The gas supply shall be shut off prior to disconnecting the electrical power, before proceeding with the conversion**
  - If for any reason the **Orifice Holder** is removed, ensure it is carefully set and remounted back onto the venturi in **perfect centre alignment** before securing with screws. Failure to do so could result in poor combustion or damage to the heater.
1. Remove the **# 38 NG Orifice** in a counter clockwise rotation using an 11/16" or 19mm box wrench.
  2. Screw in the **# 50 LP Orifice** supplied with the kit all the way until it is snug, **do not over tighten.**
  3. Convert the **Combination Gas Valve**: Refer to Instruction sheet included with the **Honeywell** valve conversion kit
  4. With the heater in operation, use a manometer to check and adjust the manifold gas pressure. Regulate the gas pressure to **10" w.c.** by turning the **Adjustment Screw** clockwise to increase, and counter clockwise to reduce manifold pressure.
  5. With manifold pressure correctly set, insert new O-ring and fit the new Adjustment Screw Cap into the Valve.
  6.  re to seal adjustment port will result in gas leakage from the port
  7. Affix **Valve Conversion Label** to the gas valve.
  8. Print Date, Company Name & Address on **Conversion Kit Rating Plate** and affix the plate to the heater in the proximity of the CSA rating plate
  9. **Return to General Instructions and complete all steps of leak testing and commissioning**

